

> > Joel

> >

> >

> > ----- Original Message -----

> > From: "Phil Hailes" <Phil-H@ipsc.com>

> > To: <joel@advancedburner.com>

> > Sent: Thursday, September 11, 2003 12:25 PM

> > Subject: PA Mass Flow

> >

> >

> > > At 950 MW with 7 mills, the PA mass flow is approximately 3,500

> > lbs/hr

> > > per mill.

> > >

> > >>> "joel" <joel@advancedburner.com> 9/10/2003 1:16:18 PM >>>

> > > Phil:

> > >

> > > We need ASAP the following:

> > >

> > > What is the primary air flow per mill with the boiler at full load

> > > with

> > > 7 mills in service? This value will set our nozzle sizing..

> > >

> > >

> > >

> > > Joel Vatsky

> > >

> > >

> > >

> >

> >

>

>